

CONFIDENTIAL

DATE	REV	RECORD	DR
11/21	A	SUBMITTAL	JK

3/4" NPT DRAIN
(OPTIONAL LOCATIONS)

2"
8"

ULTRA-SORB LH VERTICAL

STEAM INLET
(OPTIONAL LOCATIONS)

PITCH

AIRFLOW

3/4" NPT DRAIN
(OPTIONAL LOCATIONS)

12" RECOMMENDED CLEARANCE

36" RECOMMENDED CLEARANCE

VAPORMIST HUMIDIFIER

12"
2"

PITCH

PITCH

FUNNEL

TEMPERED DRAIN WATER

VACUUM BREAKER

COLD WATER INLET
3/8" NPT

NOTE: PROVIDE 1" AIR GAP TO ELIMINATE BACK SIPHONAGE

NOTE:
VERIFY THAT MAXIMUM FLOW OF HOT WATER INTO THE DRANE KOOLER DOES NOT EXCEED 6 USGPM (22.7 L/M)

DRANE-KOOLER

FLOOR DRAIN

SANITARY SEWER



VAPORMIST, US-LH VERTICAL WITH DRANE KOOLER

MAT'L:

SCALE: 1:25
DRAWN BY: JK
DATE: 11/3/21

P/N

GENERIC SUBMITTAL