

# SCHNEIDER MS51-7XXX SERIES VALVE W/JCI 6703 HUMIDISTAT

DATE	REV	RECORD	DR
2/11	A	E.C.# 5299	JK
5/11	B	E.C.# 5396	AJK
3/13	C	E.C.# 6039	JK

CONFIDENTIAL


120 VOLT AC PRIMARY  
 CLASS 2 TRANSFORMER, TYPE AT72D1006  
 40 VA (BY DRI-STEEM, #408700-001)

\* OPTIONAL

\* HIGH LIMIT HUMIDISTAT

\* AIR FLOW SWITCH


\* ELECTRIC HIGH TEMP



JCI HC-6703-4NDOW HUMIDISTAT (ROOM)  
 OR  
 JCI HC-6703-6NDOP HUMIDISTAT (DUCT)

JUMPER SET ON 0-10 VDC OUTPUT AT FACTORY


JUMPERS SET ON RA (REVERSE ACTING) AT FACTORY



2-10 VOLT DC SIGNAL  
 COMMON

SCHNEIDER MS51-7XXX SERIES ELECT. MODULATING ACTUATOR

YEL/BLK BLACK  
 RED



NORMALLY CLOSED VALVE BODY  
 VALVE CLOSES AT 2 VOLT

		SCHNEIDER MS51-7XXX SERIES VALVE W/JCI 6703 HUMIDISTAT	
		MAT'L:	P/N
SCALE:	DATE: 2/14/11	VLV-93	
DRAWN BY: KROG			