


STS® DL EVAPORATIVE HUMIDIFIER

DATE	REV	RECORD	DR
12/24	A	E.C.# 7334	JK




POWER WIRING
CONTROL CIRCUIT
WIRING

FIELD WIRING
OPTIONAL FACTORY
.....
OPTIONAL FIELD

NOTES:

1. WIRING AND BRANCH CIRCUIT PROTECTION PROVIDED BY INSTALLER AS PER NATIONAL ELECTRICAL CODE.
2. FOR SUPPLY AND MACHINE GROUND CONNECTIONS, SIZE WIRE USING 75°C WIRE TABLE PER NATIONAL ELECTRICAL CODE.
3. USE COPPER CONNECTORS RATED FOR 105°C.

- 4 IF THE INTERLOCK SWITCH IS NOT USED, THEN WIRE DIRECTLY TO TERMINAL SWITCH.
5. REFER TO STS ELECTRICAL DATA SHEET.
- 6 REMOVE SHUNT J404 FROM BOARD IF USING OPTIONAL ACCESSORY.



LEGEND

K	RELAY/CONTACTOR	Y	SOLENOID
T	TRANSFORMER	N	SENSOR
S	CIRCUIT BREAKER	J	JUMPER
Q	SWITCH	E	WATER PROBE
H	HEATER	M	MOTOR/FAN

driSteem 

SCALE:
DRAWN BY: JK
DATE: 12/19/24

STS-CE-VL-24