


STS[®] EVAPORATIVE HUMIDIFIER

WIRING DIAGRAM W/VL[®]

DATE	REV	RECORD	DR
12/24	A	E.C.# 7334	JK




POWER WIRING
CONTROL CIRCUIT
WIRING
FIELD WIRING
OPTIONAL FACTOR
.....
OPTIONAL FIELD

NOTES:

1. WIRING AND BRANCH CIRCUIT PROTECTION PROVIDED BY INSTALLER AS PER NATIONAL ELECTRICAL CODE.
2. FOR SUPPLY AND MACHINE GROUND CONNECTIONS, SIZE WIRE USING 75°C WIRE TABLE PER NATIONAL ELECTRICAL CODE.
3. USE COPPER CONNECTORS RATED FOR 105°C.


4. IF THE INTERLOCK SWITCH IS NOT USED, THEN WIRE DIRECTLY TO TERMINAL SWITCH.
5. REFER TO STS ELECTRICAL DATA SHEET.
6. REMOVE SHUNT J404 FROM BOARD IF USING OPTIONAL ACCESSORY.



BREAK TO EXTERNAL CONNECTIONS DIAGRAM

LEGEND

K	RELAY/CONTACTOR	Y	SOLENOID
T	TRANSFORMER	N	SENSOR
Q	CIRCUIT BREAKER	J	JUMPER
S	SWITCH	E	WATER PROBE
H	HEATER	M	MOTOR/FAN

		STS, STD WATER, ELECT. ACTUATOR, CONTROLLED VLV BY OTHERS, 2-10VDC OR 4-20MA	
		MAT'L:	
		SCALE:	P/N STS-VL-23
		DRAWN BY: JK	
		DATE: 12/18/24	