



- NOTES:**
1. WIRING AND BRANCH CIRCUIT PROTECTION PROVIDED BY INSTALLER AS PER NATIONAL ELECTRICAL CODE.
 2. FOR SUPPLY HEATER AND MACHINE GROUND CONNECTIONS, SIZE WIRE USING 75°C WIRE TABLE PER NATIONAL ELECTRICAL CODE.
 3. USE COPPER CONNECTORS RATED FOR 105°C.

- △ 4 FOR 230 & 400 VOLT
- △ 5 FACTORY OPTION
- 6 REFERENCE OUTDOOR ENCLOSURE DIAGRAM #XTP-V2-OE-1

XTP DUAL CYLINDER, XTP 083
W/FUSES 380/400/480 VOLT,
XTP 067 W/FUSES 380/400 VOLT

SCALE: _____ P/N XTP-V2-VL-5
DRAWN BY: JK
DATE: 12/11/25

BREAK TO EXTERNAL CONNECTIONS DIAGRAM